



NOTES:

1. MUST USE RECTANGULAR BOX TO ACCOMMODATE BOTH THE SUB-METER AND SHUT-OFF VALVE.
2. MUST HAVE SHUT-OFF VALVE ON INLET SIDE BEFORE METER.
3. MUST PLACE SUB-METER BOX WITHIN 5 FEET OF MAIN METER, EASILY ACCESSIBLE TO METER READER. (UNLESS APPROVED BY THE PUBLIC WORKS DEPARTMENT)
4. MUST CALL METER SHOP AT 305-673-7681 WHEN INSTALLATION IS COMPLETED FOR FINAL INSPECTION IN ORDER TO OBTAIN SEWER CREDIT.
5. SUB-METER MUST BE ONE SIZE SMALLER THAN THE DOMESTIC METER.
6. SUB-METER SHALL NOT BE LOCATED MORE THAN 2 FEET FROM THE RIGHT-OF-WAY LINE.
7. SUB-METER SHALL BE LOCATED WITHIN THE RIGHT OF WAY UNLESS IT WILL BE USED FOR THE COOLING TOWER. (EXISTING DEVELOPMENTS)